

IT-Kühlung-Lösung



“Moin Moin”



worum geht es überhaupt ?




ESO 9802 ASF
18/12 – AT35°C

$Q_0 = 1.000 \text{ kW (962 kW)}$
EER 3,89
100% FC = AT 2°C

Luft

$V = 352.000 \text{ m}^3/\text{h}$
Fans 16*1,67 kW




Ball – $\varnothing 87\text{m}$

A380

Spannweite – 79,30 m

Länge – 72,30 m



worum geht es überhaupt ?



ESO 9802 ASF
18/12 – AT35°C

$Q_0 = 1.000 \text{ kW}$ (962 kW)
EER 3,89
100% FC = AT 2°C

Wasser




$V = \sim 150 \text{ m}^3/\text{h}$

$\Delta p = 138 \text{ kPa}$

Pumpe – 7,5 kW

$138 \text{ kPa} \times 150.000$

pool 10 x 10 x 1,5m



worum geht es überhaupt ?



ESO 9802 ASF
18/12 – AT35°C

$Q_0 = 1.000 \text{ kW (962 kW)}$
EER 3,89
100% FC = AT 2°C

Strom

P-el = 247,5 kW



kW – thermal = °C



$\text{CO}_2 = \sim 127 \text{ kg/h}$

V8 = ~ 337 HP



kW – mechanical = km/h



$\text{CO}_2 = \sim 0,2 \text{ kg/km}$

worum geht es überhaupt ?



ESO 9802 ASF
18/12 – AT35°C

$Q_0 = 1.000 \text{ kW (962 kW)}$
EER 3,89
100% FC = AT 2°C

Kältemittel

$T_C = 49,3^\circ\text{C}$
 $T_{HG} = 65,0^\circ\text{C}$
 $T_0 = 9,8^\circ\text{C}$



$m = 2 \times 12.222 \text{ kg/h}$

temperature level = ~ 65°C

velocity = ~ 25 m/s = ~ 90 km/h



HOT



chiller basics - point of reference



chilled water

A 35°C

B 18°C ——— inlet / entering
C 12°C ——— outlet / leaving

D 700 kW

E 8.760 h/a


F DX - MIX - FC

G < OPEX

CHW – L = const !



chiller basics - what is energy efficiency



energy efficiency =

the goal to reduce the amount of energy to provide required products and services !

$$EER = \frac{Q_0}{P-el}$$

Q_0

P-el

700 kW

cmprs - fans - pumps



chiller basics – fluids in motion



fluids

- air fans = 8.760 h/a
- water pumps = 8.760 h/a
- refrigerant cmpr < 8.760 h/a

operation modes

- DX
- MIX
- FC



CyberCool 2

**Glycol / Non-Glycol
Netzwerk Kälteeffizienz
30.09.2015**



Chiller Team

Agenda

- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH / CRAC
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - Fazit

CHW System Design p/s




Primärkreislauf/ Chiller

erzeugt Kaltwasser


Sekundärkreislauf / CRAH

verbraucht Kaltwasser



8.760 h/a
12°C

CHW System Design p/s



A

EG 30 < EG 0

B

EG 30 > EG 0

Chiller Design Glycol / Non-Glycol



FC – Register



DX – Verdampfer



Glycol

Non - Glycol

|

|

Glycol

Glycol

Glycol

Wasser

Agenda

- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH / CRAC
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - Fazit

System Design Parameter

Chiller / primär


- Kühllast 700 kW
- CHW temp. 18 / 12°C
- AT 35°C

CRAH / sekundär

- Raum Bedingungen 28°C / 40% r.H.

Annahme

- scenario A: CHW-Media / EGO
- scenario B: CHW-Media / EG30



Agenda

- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - Fazit

CRAH

<u>Unit</u>	<u>Scenario A - EGO</u>	<u>Scenario B - EG30</u>
Unit type:	ASD 1000 CW	ASD 1000 CW
Cooling capacity (total):	79,8 kW	71,8 kW
Cooling capacity (sensible):	79,8 kW	71,8 kW
Net total cooling capacity:	76,2 kW	68,2 kW
Net sensible cooling capacity:	76,2 kW	68,2 kW

Air (Data per unit)

Airflow:	20.000 m ³ /h	20.000 m ³ /h
Return air temperature:	28 °C	28 °C
Return air humidity:	40 rel. %	40 rel. %

Hydraulics (Data per unit)

Medium inlet temperature:	12,0 °C	12,0 °C
Medium outlet temperature:	18,0 °C	18,0 °C
Medium volume flow:	11,4 m ³ /h	11,1 m ³ /h
Percentage of glycol:	0 %	30 %



Einfluss Glykol/ EGO – EG30

- Kälteleistung: ca. - 10%
- Volumenstrom: ca. - 5%



Agenda

- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - Fazit

Glycol Faktor (Chiller Volumenstrom)

Chiller / primär

- Kälteleistung 700 kW
- CHW temp. 18 / 12°C
- c – EGO 4,2 kJ/(kg K)
- c – EG30 3,8 kJ/(kg K)

$$Q = m * c * \Delta T \qquad Q = \frac{m^3}{s} * \frac{kJ}{kg * K} * K = W$$

Annahme

- Scenario A: approx. 100 m³/h (EG0)
- Scenario B: approx. 110 m³/h (EG30)



Einfluss Glykol/ EGO – EG30

- Volumenstrom: approx. + 10%



Glycol Faktor (CHW Pumpe)

Chiller / primär

- Kälteleistung 700 kW
- Druckverluste 150 kPa (EG0); 170 kPa (EG30)
- Effizienz Pumpe 0,7
- Scenario A: approx. 100 m³/h (EG0)
- Scenario B: approx. 110 m³/h (EG30)

$$P - el = \frac{V * \Delta p}{\eta} \quad P - el = \frac{\frac{m^3}{s} * \frac{N}{m^2}(Pa)}{-} = \frac{Nm}{s} = W$$

Annahme

- Scenario A: approx. **6,0 kW** / 7,5 kW (EG0)
- Scenario B: approx. **7,4 kW** / 11 kW (EG30)



CHW-Pumpe


- in Betrieb 8.760 h/a

Agenda


- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - Fazit


System Design

Glycol




Non-Glycol



- P-el / FC Pumpe
 - PWT / Grädigkeit
 - PWT - CHW Zwangsdurchströmung
- 

System Design


Glycol



dp 3-Wege Ventil

- 700 kW (100m³/h) dp= 30 kPa
- **K= ca. 1.575 €/a** (15 ct/kWh)

Non-Glycol



dp PWT - CHW

- 700 kW (100m³/h) dp= 70 kPa
- **K= ca. 3.680 €/a** (15 ct/kWh)

System Design

FC Pumpe Betrieb

- 700 kW; 18/12 – EG30
- P-el = 12 – 18 kW (15 ct/kWh)
- Hamburg – MIX ca. 5.000 h/a
- Hamburg – FC ca. 2.250 h/a


Betriebsmodus – Mix

- 12 kW **K = ca. 9.000 €/a**
- 18 kW **K = ca. 13.500 €/a**

Betriebsmodus – Mix + FC

- 12 kW **K = ca. 13.050 €/a**
- 18 kW **K = ca. 19.575 €/a**



Non-Glykol



Agenda

- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - Fazit

operation modes





Start Mix - CHW entering temp.



Start FC - CHW leaving temp.









Aktive Chiller Komponenten 18/12 – EG30 w/o Systemtrennung / kein PWT





DX
~ 1.449 h/a
(17%)

Mix – DX / FC
~ 5.062 h/a
(58 %)

FC – 100%
~ 2.249 h/a
(25 %)

FC	DX	Fan
		
		
		
~ 7.311 h/a (83 %)	~ 6.511 h/a (75 %)	~ 8.760 h/a (100 %)

Betriebszustände – Kaltwassersatz luftgekühlt 18/12 – 35 AT



DX
~ 1.449 h/a
(17%)

Mix – DX / FC
~ 5.062 h/a
(58 %)

FC – 100%
~ 2.249 h/a
(25 %)



TGA / Komfort - Klimatisierung

Freikühl- Philosophie

Betriebskostenberechnung

- Scenario A) Non-Glycol (PWT - 2K)
- Scenario A+) Non-Glycol (PWT - 5K)
- Scenario B) Glycol
- Standort: Hamburg 18/12 – AT35




Temp.	Hours	Status	DX Capacity	FC Capacity	LWT (FC)	Total Capacity	Compressor			Fans/Axitop		Pump		FC-Pump		Total
[°C]	[h/a]	[-]	[kW]	[kW]	[°C]	[kW]	[kW]	[kWh/a]	[kW]	[kWh/a]	[kW]	[kWh/a]	[kW]	[kWh/a]	[kWh/a]	
17	357	DX	752	0	0,0	752	95.1	33.951	19,2	6.854	0,0	0			40.805	
16	348	MIX	639	113	17,1	752	57.8	20.114	22,8	7.934	0,0	0			28.048	
15	395	MIX	590	162	16,7	752	54.4	21.488	22,8	9.006	0,0	0			30.494	
14	419	MIX	541	211	16,3	752	49.3	20.657	22,8	9.553	0,0	0			30.210	
13	346	MIX	492	260	15,9	752	44.2	15.293	22,8	7.889	0,0	0			23.182	
12	337	MIX	442	310	15,5	752	40.8	13.750	22,8	7.684	0,0	0			21.434	
11	394	MIX	393	359	15,1	752	35.7	14.066	22,8	8.983	0,0	0			23.049	
10	379	MIX	344	408	14,7	752	30.6	11.597	22,8	8.641	0,0	0			20.238	
9	408	MIX	295	457	14,4	752	27.2	11.098	22,8	9.302	0,0	0			20.400	
8	445	MIX	246	506	14,0	752	22.1	9.835	22,8	10.146	0,0	0			19.981	
7	473	MIX	197	555	13,6	752	18.7	8.845	22,8	10.784	0,0	0			19.629	
6	435	MIX	147	605	13,2	752	13.6	5.916	22,8	9.918	0,0	0			15.834	
5	396	MIX	98	654	12,8	752	8.5	3.366	22,8	9.029	0,0	0			12.395	
4	368	MIX	49	703	12,4	752	5.1	1.877	22,8	8.390	0,0	0			10.267	
3	356	FC	0	752	12,0	752	0.0	0	19,2	6.835	0,0	0			6.835	



Scenario B)

Beispiel –
Software CC2

Freikühl- Philosophie




70






68

Temp.	Hours	Status	DX Capacity	FC Capacity	LWT (FC)	Total Capacity	Compressor		Fans/Axitop		Pump		FC-Pump		Total
[°C]	[h/a]	[-]	[kW]	[kW]	[°C]	[kW]	[kW]	[kWh/a]	[kW]	[kWh/a]	[kW]	[kWh/a]	[kW]	[kWh/a]	[kWh/a]
17	357	DX	752	0	0,0	752	95,1	33.951	19,2	6.854	0,0	0			40.805
16	348	MIX	639	113	17,1	752	57,8	20.114	22,8	7.934	0,0	0			28.048
15	395	MIX	590	162	16,7	752	54,4	21.488	22,8	9.006	0,0	0			30.494
14	419	MIX	541	211	16,3	752	49,3	20.657	22,8	9.553	0,0	0			30.210
13	346	MIX	492	260	15,9	752	44,2	15.293	22,8	7.889	0,0	0			23.182
12	337	MIX	442	310	15,5	752	40,8	13.750	22,8	7.684	0,0	0			21.434
11	394	MIX	393	359	15,1	752	35,7	14.066	22,8	8.983	0,0	0			23.049
10	379	MIX	344	408	14,7	752	30,6	11.597	22,8	8.641	0,0	0			20.238

operation modes - characteristics




MIX mode problem




$$\Delta p = p_c - p_0$$

$$\Delta p = \text{lift}$$



Mix mode problem



lowering fan speed
DX (+) FC (-)



shutting off DX coils
DX (-) FC (+)




ICS valve / CC2 stand.
DX (+) FC (+)


Agenda

- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - Fazit

Hamburg / aktive Chiller Komponenten 18/12



Glykol / Non-Glykol; Hamburg 700 kW 18/12



Scenario B
EG 30
DX - MIX - FC

Scenario A
EG 0 / 2K
DX - MIX - FC

Scenario A
EG 0 / 5K
DX - MIX - FC



190.647 + 157.902 + 0
348.549 kWh/a

257.323 + 158.325 + 0
415.648 kWh/a

351.173+ 160.380 + 0
511.552 kWh/a



48.178 + 144.004 + 25.817
217.999 kWh/a

68.982 + 140.896 + 24.328
234.206 kWh/a

98.322 + 131.796 + 7.578
237.695 kWh/a



CHW
7,5/11 kW

10.868 + 55.682 + 24.739
91.289 kWh/a

18.908 + 55.352 + 13.277
87.537 kWh/a

30.128 + 49.357 + 2.816
82.301 kWh/a



FC
15 kW

0 + 0 + 0
0 kWh/a

0 + 75.480 + 18.105
93.585 kWh/a


0 + 67.305 + 3.840
71.145 kWh/a

657.837 kWh/a

830.976 kWh/a

902.693 kWh/a

Glycol / Non-Glycol; Hamburg 700 kW 18/12 (15 ct/kWh)


**Scenario B
EG 30**

DX - MIX - FC

 348.549 kWh/a
52.282 €/a

**Scenario A
EG 0 / 2K**

DX - MIX - FC

 415.648 kWh/a
62.347 €/a
**Scenario A
EG 0 / 5K**

DX - MIX - FC

 511.552 kWh/a
76.732 €/a

 217.999 kWh/a
32.700 €/a

 234.206 kWh/a
35.131 €/a

 237.695 kWh/a
35.654 €/a

 CHW
 7,5/11 kW

 91.289 kWh/a
13.693 €/a

 87.537 kWh/a
13.130 €/a

 82.301 kWh/a
12.344 €/a


 FC
 15 kW

 0 kWh/a
0 €/a

 93.585 kWh/a
14.037 €/a

 71.145 kWh/a
10.671 €/a
98.675 €/a
124.645 €/a
135.401 €/a

CHW System Auswertung



	Chiller	CHW-Pumpe	Glykol (5+5m ³)	CRAH
SYSTEM-CAPEX				
EG 30	-	~ 1.500 €	~ 30.000 €	-
EG 0 – 2 K	2 x ~25.252 €	-	-	-
EG 0 – 5 K	2 x ~15.151 €	-	-	-
SYSTEM-OPEX				
EG 30	-	~ 1.500 €/a	-	~ 2.000 €/a
EG 0 – 2 K	~ 25.970 €/a	-	-	-
EG 0 – 5 K	~ 36.726 €/a	-	-	-

Agenda

- Glycol / Non-Glycol
 - CHW - System Design p/s
 - Beispiel Rechenzentrum
 - CRAH
 - Glykol Faktor (Chiller / Pumpe)
 - System Design G / NG
 - System Operational
 - Facts & Figures
 - **Fazit**

Kernaussagen

Systemvergleich - OPEX



- Glykol: **~ 102.175 €/a**

●———— ROI < 1 Jahr
- Non-Glycol (2K): ~ 124.645 €/a (+22% - spec CC2)

●———— ROI < 1.5 Jahre
- Non-Glycol (5K): ~ 135.401 €/a (+32% / +9%)

Fazit 1/2 - chiller

Glykol



CAPEX (-)
OPEX (-)

Non - Glykol



CAPEX (+)
OPEX (+)



Δp (+)
TTD (+)



P_{el} (+)
h/a (+)



P_{el} (+)
h/a (+)



Fazit 2/2 - System

Glykol

|

Chiller (+)
CRAH (-)

Non - Glykol

|

Chiller (-)
CRAH (+)

Energie Effizienz

|

Glykol >> Non- Glykol



questions & answers



STULZ GmbH
IT Cooling Solutions and Services
Vertrieb Export

E-Mail: roemer@stulz.de
Tel: +49 40 5585 2262
Mobil: +49 163 8592839



“Tschüss”

